

GOVT. OF NCT DELHI
QUALITY CONTROL ZONAL LABORATORY
TRANS YAMUNA REGION TAHIRPUR DELHI-110093.

ACWA-TYR
 Diary No. 70 dt. 26/2/18

Dated: 22-02-2018

NO: DJB/ACWA(TYR)/2017.....

Analysis report of D.J.B. supply sample collected from Geeta Bal Bharti Sr. Sec. School Rajgarh Colony, Delhi-31. for drinking purpose. M/S. Raj Kumar Sharma, Geeta Bal Bharti (Sr. Sec. School) Rajgarh Colony, Delhi-31. Letter No. GBB/2017-18/126/14893 dated 15-02-2018.

Date of collection: 20-02-2018

Challan No. 375


Dated : 16-02-2018

S. No.	PARTICULARS	LIMITS	UNIT	RESULTS
A.	Physical Examination		
1.	Colour		Clear
2.	Odour		Chlorinuos
3.	Turbidity	(1-5)		<2.0
4.	pH Value	(6.5 to 8.5)		7.5
5.	Electrical Conductivity	--		183
6.	Total Dissolved Solids	(500-2000)	mg/l	120
B.	Chemical Examination			
1.	Nitrate	45		0.6
2.	Nitrite		NIL
3.	F/s Ammonia		NIL
4.	Chloride	(250-1000)	mg/l	8
5.	Fluoride	(1.0-1.5) (200-400)	"	0.20
6.	Sulphate	"	28
7.	pH Alkalinity	"	NIL
8.	Free Carbondioxide	(200-600)	"	4
9.	Total Alkalinity	(200-600)	"	58
10.	Total Hardness	(75-200)	"	84
11.	Calcium as (Ca)	(30-100)	"	22.4
12.	Magnesium as (Mg)	(0.3)	"	6.72
13.	Total Iron	...	"	0.06
14.	Residual Chlorine		"	1.0
15.	Bacteriological Examination Coliform Count	MPN/100		0

This Report
Pertains To
The Particular
Sample Only

REMARKS :- On the basis of tested parameters, the above water sample confirm the drinking water specifications BIS: 10500-2012 and fit for drinking purpose.


 Asstt. Chemist


 22/02/18
 Chemist


 22/2/18
 ACWA (TYR)

Asstt. Chief Water Analyst
 D.J.B. Govt. of N.C.T. of Delhi
 Quality Control Zonal Laboratory (Tyr)
 Tahir Pur Dilshad Garden, Delhi-9.

East Delhi Municipal Corporation

Public Health Department
Shahdara (South) Zone
Karkardooma, Shahdara, Delhi-110092

No. DHO/Shah.(S)/2018/D- 390

Dated:- 19/3/18


School Health Certificate

- | | | |
|------------------------------------|---|--------------------------------|
| 1. Name of the School | : | Geeta Bal Bharti Sr Sec School |
| 2. Location of the School | : | Rajgarh Colony ,Delhi-31 |
| 3. Timing of School | : | 07.45 AM to 01.45PM |
| 4. No. of Student | : | 1510(Boys-1074,Girls-436) |
| 5. No. of Rooms | : | 85 |
| 6. No. of Doors in each room | : | Provided |
| 7. No. of Windows in each room | : | Provided |
| 8. Desk & Chairs | : | Provided |
| 9. No. of Urinals Toilets for Boys | : | 14 |
| 10. No. of W.C for Girls | : | 26 |
| 11. School Building | : | Pucca |
| 12. Electricity | : | BSES |
| 13. Drinking Water | : | Available |
| 14. No. Of Staff | : | 70 |

At the time of inspection, school is found running under satisfactory sanitary conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

Head of School
Geeta Bal Bharti School
Rajgarh Colony ,Delhi-31


Deputy Health Officer
Shahdara (South) Zone
East Delhi Municipal Corporation